

Scenario — PV

GEMINI-60-house-with-garage Germany - Grünheide 52.40100, 13.84200

Name	Slope °	Azimuth °	Wp	Wall d/h m	Face	Bifacial	Wp counted
Roof East	22	-90	19800	—	front	—	yes
Roof West	22	90	19800	—	front	—	yes
Terrace railing south	90	0	4620	5 / 4	front	—	yes
Terrace railing north	90	180	4620	5 / 4	front	—	yes
Garage roof	1	0	10740	—	front	—	yes
Garage side wall south	90	0	3475	5 / 4	front	—	yes
Garage side wall north	90	180	3475	5 / 4	front	—	yes
Garage door side west	90	90	700	5 / 4	front	—	yes
Garage back side east	90	-90	2540	5 / 4	front	—	yes
Garden fence east	90	-90	6000	5 / 4	face 1	—	yes
Garden fence east face2	90	90	4800	5 / 4	face 2	80 %	no
Total counted			75770				

Database PVGIS-SARAH3 2005–2023 loss 14 % azimuth 0 = south, 90 = west, –90 = east.

Peak hour 2023-05-08 10:11 UTC 42037 W 0.555 W/Wp of 75770 Wp.

Database gaps: 10 days with 0 yield while the sun reached the horizon at noon. 2008-01-23, 2008-03-01, 2008-03-06, 2008-05-17, 2008-05-18, 2009-04-18, 2009-04-19, 2009-08-15, 2009-08-16, 2016

Sell when the export price is above 0. At 0 cent export PV yield only, not the battery. Do not sell when the earning is negative. At 15:00 winter time, battery export is only the kWh that would not fit in the

Scenario — house, heat pump, battery
GEMINI-60-house-with-garage Germany - Grünheide 52.40100, 13.84200

Chapter	Parameter	Value
Building	Design out / in / heat	-10.0 °C / 20.0 °C / 1600.0 W
	Heat on / cool on / ground	22.0 °C / 25.0 °C / 10.0 °C
	Curve / flow min / max	0.4 / 25.0 °C / 55.0 °C
	Thermal mass of the house	25.0 kWh/K
	Household only	4.0 kWh/day
DHW	Litres at 40 °C / tank	200.0 L tank 42.0 °C 8-18 h
	Water out of the pipe Q1-Q4	8 °C 10 °C 12 °C 10 °C
Heat pump	Source	air and ground
	COP –10/0/10 @ 35 °C	2.4 3.4 4.5
	COP –10/0/10 @ 50 °C	1.9 2.6 3.3
	kW –10/0/10 @ 35 °C	4 5 6
	kW –10/0/10 @ 50 °C	3.5 4.5 5
Battery	kWh / C-rate / SOC min-max-start	176.8 kWh C 0.5 5 / 95 / 50 %
	Nameplate	—
	Charge / discharge η	95 % / 90 %
Grid	Inverter / grid connection	34.0 kW / 0.0 kW
	Max export	0.0 kW
	Import cap Jan-Jun kW	Jan 2 Feb 2 Mar 2 Apr 2 May 2 Jun 2
	Import cap Jul-Dec kW	Jul 2 Aug 2 Sep 2 Oct 2 Nov 2 Dec 2
Cars	Lunch DC / night AC	0.0 kWh @ 30.0 kW night 10.0 kWh @ 11.0 kW


Records 1-10 — contribution of each PV
Germany - Grünheide 52.40100, 13.84200

PV	2023-05-08 10:11	2009-06-13 10:11	2021-05-30 10:11	2009-06-13 11:11	2023-05-09 10:11	2023-05-17 10:11	2023-05-08 11:11	2011-05-03 10:11	2023-05-17 11:11	2020-05-15 10:11
Roof East	14769	14948	14835	13969	14639	14600	13423	14265	13413	14337
Roof West	12194	12487	12462	14276	12098	12217	13930	11752	13894	12006
Terrace railing south	2697	2232	2347	2339	2651	2505	2767	2723	2583	2504
Terrace railing north	150	185	161	157	149	190	149	207	189	171
Garage roof	7876	7979	7940	8211	7809	7806	7976	7587	7938	7665
Garage side wall south	2029	1679	1766	1759	1994	1884	2082	2048	1943	1884
Garage side wall north	113	139	121	118	112	143	112	156	143	129
Garage door side west	23	28	24	70	23	29	71	31	77	26
Garage back side east	604	616	596	87	596	604	82	626	104	595
Garden fence east	1427	1456	1408	204	1408	1426	194	1479	246	1405
Garden fence east face2	156	192	168	478	155	197	487	215	531	178
Watt at record	42037	41943	41829	41669	41633	41600	41274	41089	41062	40901
Percent of installed peak	55.5	55.4	55.2	55.0	54.9	54.9	54.5	54.2	54.2	54.0


Hours at or above a share of the record
Germany - Grünheide 52.40100, 13.84200

Of the record	Hours	Watts
98 %	7	41196 W
96 %	34	40355 W
94 %	130	39514 W
92 %	359	38674 W
90 %	732	37833 W


Yield distribution for each day — W_h / W_p of all PV together
Germany - Grünheide 52.40100, 13.84200




Yield distribution for each day — Wh / Wp of all PV together — 00:00-09:00
Germany - Grünheide 52.40100, 13.84200




Yield distribution for each day — Wh / Wp of all PV together — 15:00-23:59
Germany - Grünheide 52.40100, 13.84200




Share of the day's yield in 09:00-15:00 winter time
Germany - Grünheide 52.40100, 13.84200




Share of the day's yield outside 09:00-15:00 winter time
Germany - Grünheide 52.40100, 13.84200




Highest temperature of each day
Germany - Grünheide 52.40100, 13.84200




Average temperature of each day
Germany - Grünheide 52.40100, 13.84200



Lowest temperature of each day
Germany - Grünheide 52.40100, 13.84200



Difference between highest and lowest temperature of each day
Germany - Grünheide 52.40100, 13.84200



Monthly and yearly specific yield (kWh/kWp = Wh/Wp)
Germany - Grünheide 52.40100, 13.84200

Month / year		Roof East 22°/-90° 19800 Wp	Roof West 22°/90° 19800 Wp	Terrace railing south 90°/0° 4620 Wp	Terrace railing north 90°/180° 4620 Wp	Garage roof 1°/0° 10740 Wp	Garage side wall south 90°/0° 3475 Wp	All together
January	Maximum	20.16	18.91	3.76	3.76	19.70	3.76	14.40
	average	14.84	14.23	3.30	3.30	14.72	3.30	11.10
	minimum	10.53	11.23	2.31	2.31	11.07	2.31	8.25
February	Maximum	44.95	41.24	7.15	7.15	43.98	7.15	31.60
	average	30.54	29.64	5.98	5.98	30.56	5.98	22.64
	minimum	21.53	19.68	5.16	5.16	20.52	5.16	16.16
March	Maximum	87.48	84.29	23.43	13.84	88.81	23.43	63.30
	average	62.69	61.94	18.39	12.22	64.12	18.39	47.67
	minimum	49.45	47.99	14.69	10.63	50.29	14.69	38.37
April	Maximum	124.16	123.55	77.10	21.79	128.82	77.10	98.74
	average	100.05	97.80	60.12	19.65	102.54	60.12	80.08
	minimum	81.51	79.77	45.74	15.53	83.24	45.74	65.66
May	Maximum	153.12	144.55	88.40	30.15	155.08	88.40	120.65
	average	121.83	118.06	71.07	26.56	124.57	71.07	98.63
	minimum	73.62	76.00	42.22	23.70	77.15	42.22	62.65
June	Maximum	152.64	151.42	78.56	30.50	159.19	78.56	121.81
	average	126.50	124.72	66.05	28.34	130.75	66.05	102.32
	minimum	107.53	101.58	56.73	25.71	108.35	56.73	86.67
July	Maximum	150.14	145.20	81.86	32.29	154.39	81.86	119.94
	average	122.45	121.02	67.93	29.21	126.71	67.93	100.06
	minimum	98.44	99.71	54.22	25.66	102.62	54.22	81.46
August	Maximum	122.23	123.81	83.09	25.32	128.99	83.09	100.54
	average	105.74	103.17	65.77	22.56	108.33	65.77	85.77
	minimum	90.42	87.59	53.88	19.70	91.99	53.88	73.47
September	Maximum	91.39	88.12	39.64	16.45	91.99	39.64	68.48
	average	77.01	74.54	32.67	14.24	78.25	32.67	59.05
	minimum	61.07	59.22	25.89	12.66	61.52	25.89	47.58
October	Maximum	52.17	60.38	8.98	8.96	56.82	8.98	40.79
	average	43.03	42.25	8.45	8.43	43.55	8.45	32.13
	minimum	27.53	26.07	7.12	7.11	27.43	7.12	20.90
November	Maximum	27.57	28.14	4.46	4.46	28.14	4.46	20.33
	average	18.38	18.37	3.97	3.97	18.60	3.97	13.99
	minimum	13.22	12.66	3.47	3.47	13.26	3.47	10.20
December	Maximum	14.22	13.28	2.90	2.90	13.94	2.90	10.43
	average	11.33	11.43	2.49	2.49	11.35	2.49	8.70
	minimum	8.09	7.87	2.07	2.07	7.96	2.07	6.20
All years	Maximum	910.7	895.0	444.0	183.6	936.4	444.0	718.5
	average	834.4	817.2	406.2	176.9	854.0	406.2	662.1
	minimum	780.8	761.3	379.0	168.8	796.6	379.0	621.3

Highest combined yield hour: 2023-05-08 10:11 UTC 42036.6 W (0.555 W/Wp) of 75770 Wp installed. Use this hour to size battery charge power.

Monthly and yearly specific yield (kWh/kWp = Wh/Wp)
Germany - Grünheide 52.40100, 13.84200

Month / year		Garage side wall north 90°/180° 3475 Wp	Garage door side west 90°/90° 700 Wp	Garage back side east 90°/90° 2540 Wp	Garden fence east 90°/-90° + 90°/90° 6000 Wp bifacial ×80%	All together
January	Maximum	3.76	4.73	4.23	7.94	14.40
	average	3.30	4.18	3.66	7.00	11.10
	minimum	2.31	2.90	2.56	4.87	8.25
February	Maximum	7.15	9.06	7.81	14.81	31.60
	average	5.98	7.70	6.64	12.80	22.64
	minimum	5.16	6.55	5.76	11.00	16.16
March	Maximum	13.84	16.65	15.82	28.78	63.30
	average	12.22	15.28	14.45	26.68	47.67
	minimum	10.63	13.99	12.99	24.18	38.37
April	Maximum	21.79	31.26	31.26	54.72	98.74
	average	19.65	28.57	28.84	51.70	80.08
	minimum	15.53	25.96	25.45	46.21	65.66
May	Maximum	30.15	48.05	48.50	85.61	120.65
	average	26.56	41.24	43.17	76.17	98.63
	minimum	23.70	30.17	29.96	54.10	62.65
June	Maximum	30.50	47.81	46.95	84.23	121.81
	average	28.34	43.37	43.49	78.19	102.32
	minimum	25.71	39.59	40.50	72.33	86.67
July	Maximum	32.29	46.98	50.06	87.64	119.94
	average	29.21	42.92	44.18	78.52	100.06
	minimum	25.66	36.25	35.22	64.23	81.46
August	Maximum	25.32	37.90	38.32	68.24	100.54
	average	22.56	34.17	34.63	61.96	85.77
	minimum	19.70	30.59	31.57	56.06	73.47
September	Maximum	16.45	19.45	21.36	36.76	68.48
	average	14.24	17.44	18.49	32.44	59.05
	minimum	12.66	16.12	16.69	29.73	47.58
October	Maximum	8.96	10.30	11.25	19.45	40.79
	average	8.43	9.59	10.33	18.01	32.13
	minimum	7.11	7.83	8.16	14.43	20.90
November	Maximum	4.46	5.37	5.77	10.06	20.33
	average	3.97	4.68	5.02	8.77	13.99
	minimum	3.47	4.01	4.29	7.50	10.20
December	Maximum	2.90	3.31	4.56	7.10	10.43
	average	2.49	2.90	3.60	5.92	8.70
	minimum	2.07	2.35	2.54	4.42	6.20
All years	Maximum	183.6	262.2	269.1	478.9	718.5
	average	176.9	252.0	256.5	458.2	662.1
	minimum	168.8	241.6	247.2	441.2	621.3

Highest combined yield hour: 2023-05-08 10:11 UTC 42036.6 W (0.555 W/Wp) of 75770 Wp installed. Use this hour to size battery charge power.

Monthly and yearly total yield (kWh)
Germany - Grünheide 52.40100, 13.84200

Month / year		Roof East 22°/-90° 19800 Wp	Roof West 22°/90° 19800 Wp	Terrace railing south 90°/0° 4620 Wp	Terrace railing north 90°/180° 4620 Wp	Garage roof 1°/0° 10740 Wp	Garage side wall south 90°/0° 3475 Wp	All together
January	Maximum	399.1	374.4	17.4	17.4	211.5	13.1	1090.7
	average	293.8	281.8	15.2	15.2	158.1	11.5	841.2
	minimum	208.4	222.4	10.7	10.7	118.9	8.0	624.8
February	Maximum	890.0	816.5	33.0	33.0	472.3	24.8	2394.1
	average	604.6	586.8	27.6	27.6	328.2	20.8	1715.5
	minimum	426.4	389.7	23.8	23.8	220.4	17.9	1224.7
March	Maximum	1732.1	1668.9	108.3	63.9	953.8	81.4	4796.5
	average	1241.3	1226.4	85.0	56.5	688.7	63.9	3611.7
	minimum	979.2	950.2	67.9	49.1	540.1	51.0	2907.6
April	Maximum	2458.4	2446.2	356.2	100.7	1383.5	267.9	7481.3
	average	1981.0	1936.5	277.7	90.8	1101.3	208.9	6068.0
	minimum	1614.0	1579.5	211.3	71.8	894.0	159.0	4975.1
May	Maximum	3031.8	2862.0	408.4	139.3	1665.6	307.2	9141.5
	average	2412.2	2337.6	328.4	122.7	1337.9	247.0	7473.5
	minimum	1457.8	1504.8	195.0	109.5	828.6	146.7	4747.2
June	Maximum	3022.3	2998.1	363.0	140.9	1709.7	273.0	9229.8
	average	2504.8	2469.5	305.1	130.9	1404.3	229.5	7752.6
	minimum	2129.0	2011.3	262.1	118.8	1163.7	197.2	6567.3
July	Maximum	2972.7	2875.0	378.2	149.2	1658.1	284.5	9087.6
	average	2424.4	2396.3	313.8	135.0	1360.8	236.1	7581.3
	minimum	1949.0	1974.2	250.5	118.6	1102.1	188.4	6172.2
August	Maximum	2420.1	2451.4	383.9	117.0	1385.3	288.7	7618.0
	average	2093.7	2042.7	303.9	104.2	1163.5	228.5	6498.5
	minimum	1790.3	1734.2	248.9	91.0	988.0	187.2	5566.5
September	Maximum	1809.5	1744.7	183.1	76.0	988.0	137.7	5188.5
	average	1524.8	1475.8	150.9	65.8	840.4	113.5	4474.5
	minimum	1209.2	1172.6	119.6	58.5	660.7	90.0	3605.1
October	Maximum	1032.9	1195.6	41.5	41.4	610.2	31.2	3090.9
	average	852.1	836.6	39.1	39.0	467.7	29.4	2434.1
	minimum	545.2	516.1	32.9	32.8	294.6	24.7	1583.9
November	Maximum	545.9	557.2	20.6	20.6	302.2	15.5	1540.3
	average	364.0	363.7	18.3	18.3	199.7	13.8	1060.4
	minimum	261.8	250.6	16.0	16.0	142.4	12.0	773.0
December	Maximum	281.5	262.9	13.4	13.4	149.7	10.1	790.4
	average	224.3	226.4	11.5	11.5	121.9	8.6	659.4
	minimum	160.1	155.8	9.6	9.6	85.5	7.2	469.5
All years	Maximum	18032	17722	2051	848	10057	1543	54439
	average	16521	16180	1877	817	9172	1411	50171
	minimum	15459	15073	1751	780	8556	1317	47078


Highest combined yield hour: 2023-05-08 10:11 UTC 42036.6 W (0.555 W/Wp) of 75770 Wp installed. Use this hour to size battery charge power.

Monthly and yearly total yield (kWh)
Germany - Grünheide 52.40100, 13.84200


Month / year		Garage side wall north 90°/180° 3475 Wp	Garage door side west 90°/90° 700 Wp	Garage back side east 90°/90° 2540 Wp	Garden fence east 90°/-90° + 90°/90° 6000 Wp bifacial ×80%	All together
January	Maximum	13.1	3.3	10.7	47.7	1090.7
	average	11.5	2.9	9.3	42.0	841.2
	minimum	8.0	2.0	6.5	29.2	624.8
February	Maximum	24.8	6.3	19.8	88.9	2394.1
	average	20.8	5.4	16.9	76.8	1715.5
	minimum	17.9	4.6	14.6	66.0	1224.7
March	Maximum	48.1	11.7	40.2	172.7	4796.5
	average	42.5	10.7	36.7	160.1	3611.7
	minimum	36.9	9.8	33.0	145.1	2907.6
April	Maximum	75.7	21.9	79.4	328.3	7481.3
	average	68.3	20.0	73.3	310.2	6068.0
	minimum	54.0	18.2	64.6	277.3	4975.1
May	Maximum	104.8	33.6	123.2	513.7	9141.5
	average	92.3	28.9	109.7	457.0	7473.5
	minimum	82.4	21.1	76.1	324.6	4747.2
June	Maximum	106.0	33.5	119.3	505.4	9229.8
	average	98.5	30.4	110.5	469.1	7752.6
	minimum	89.3	27.7	102.9	434.0	6567.3
July	Maximum	112.2	32.9	127.2	525.9	9087.6
	average	101.5	30.0	112.2	471.1	7581.3
	minimum	89.2	25.4	89.5	385.4	6172.2
August	Maximum	88.0	26.5	97.3	409.4	7618.0
	average	78.4	23.9	87.9	371.8	6498.5
	minimum	68.5	21.4	80.2	336.4	5566.5
September	Maximum	57.2	13.6	54.2	220.6	5188.5
	average	49.5	12.2	47.0	194.6	4474.5
	minimum	44.0	11.3	42.4	178.4	3605.1
October	Maximum	31.1	7.2	28.6	116.7	3090.9
	average	29.3	6.7	26.2	108.1	2434.1
	minimum	24.7	5.5	20.7	86.6	1583.9
November	Maximum	15.5	3.8	14.7	60.4	1540.3
	average	13.8	3.3	12.8	52.6	1060.4
	minimum	12.0	2.8	10.9	45.0	773.0
December	Maximum	10.1	2.3	11.6	42.6	790.4
	average	8.6	2.0	9.1	35.5	659.4
	minimum	7.2	1.6	6.4	26.5	469.5
All years	Maximum	638	184	683	2873	54439
	average	615	176	652	2749	50171
	minimum	587	169	628	2647	47078

Highest combined yield hour: 2023-05-08 10:11 UTC 42036.6 W (0.555 W/Wp) of 75770 Wp installed. Use this hour to size battery charge power.


Export hours per day (kWh / grid kW)
Germany - Grünheide 52.40100, 13.84200



Import hours per day (kWh / grid kW)
Germany - Grünheide 52.40100, 13.84200



Emergency import hours: 2 days with an emergency: 1
Germany - Grünheide 52.40100, 13.84200



Emergency = this hour's grid import is above the month's max import kW. 2 kW means up to 48 kWh in 24 hours. More than 2 kW in an hour is the higher grid fee. Import inside that cap is not an emergency. Preferred cheap hours are 00:00-06:00 and 09:00-15:00 winter time.

Energy in kWh
Germany - Grünheide 52.40100, 13.84200

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	All
Export to grid													
month Maximum	0	0	0	0	0	0	0	0	0	0	0	0	0
month average	0	0	0	0	0	0	0	0	0	0	0	0	0
month minimum	0	0	0	0	0	0	0	0	0	0	0	0	0
day Maximum	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
day average	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
day minimum	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Import from grid													
month Maximum	132	9	0	0	0	0	0	0	0	0	0	160	211
month average	57	1	0	0	0	0	0	0	0	0	0	36	94
month minimum	0	0	0	0	0	0	0	0	0	0	0	0	0
day Maximum	18.4	9.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	17.2	18.4
day average	1.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.1	0.3
day minimum	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Total energy used for house													
month Maximum	740	661	698	604	578	516	518	515	538	607	627	723	7147
month average	677	611	644	577	548	495	498	499	513	578	609	660	6908
month minimum	639	581	616	545	519	473	487	483	484	552	593	621	6793
day Maximum	28.0	43.4	24.5	25.9	25.4	24.8	24.0	23.7	24.9	21.7	23.3	25.2	43.4
day average	21.8	21.8	20.8	19.2	17.7	16.5	16.1	16.1	17.1	18.7	20.3	21.3	18.9
day minimum	15.9	18.6	17.5	15.4	15.3	15.3	15.2	15.2	15.2	15.4	16.9	17.9	15.2

Month rows: kWh in that month. Day rows: best / average / worst day.
Total energy used for house = household + car + heating + cooling + DHW + direct electric.
PV not exported and not marked wasted is still in the battery, or could not leave because the grid was already full. It is not house use.

Energy by price
Germany - Grünheide 52.40100, 13.84200

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	All
Export													
month Maximum	0	0	0	0	0	0	0	0	0	0	0	0	0
month average	0	0	0	0	0	0	0	0	0	0	0	0	0
month minimum	0	0	0	0	0	0	0	0	0	0	0	0	0
day Maximum	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
day average	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
day minimum	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Import													
month Maximum	39	3	0	0	0	0	0	0	0	0	0	45	61
month average	17	0	0	0	0	0	0	0	0	0	0	10	27
month minimum	0	0	0	0	0	0	0	0	0	0	0	0	0
day Maximum	5.4	2.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	5.0	5.4
day average	0.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.3	0.1
day minimum	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Peak grid fee													
month Maximum	13	10	0	0	0	0	0	0	0	0	0	12	32
month average	9	1	0	0	0	0	0	0	0	0	0	6	16
month minimum	0	0	0	0	0	0	0	0	0	0	0	0	0
day Maximum	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
day average	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
day minimum	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Import incl. peak fee													
month Maximum	50	13	0	0	0	0	0	0	0	0	0	56	86
month average	26	1	0	0	0	0	0	0	0	0	0	16	43
month minimum	0	0	0	0	0	0	0	0	0	0	0	0	0
day Maximum	5.4	2.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	5.0	5.4
day average	0.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.3	0.1
day minimum	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Balance													
month Maximum	0	0	0	0	0	0	0	0	0	0	0	0	0
month average	-26	-1	0	0	0	0	0	0	0	0	0	-16	-43
month minimum	-50	-13	0	0	0	0	0	0	0	0	0	-56	-86
day Maximum	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
day average	-0.5	-0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-0.3	-0.1
day minimum	-5.4	-2.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	-5.0	-5.4

Currency in Your units. Import and export use the cent/kWh of that hour. Peak fee 6.33 / kW / month is the highest import hour of the month (hourly stand-in for the 15-minute peak) and is added to that month's Sell only when export is above 0. At 0 cent, export PV yield only, not the battery. Do not sell when the earning is negative.

Export in kWh during price hours
Germany - Grünheide 52.40100, 13.84200

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	All
Export total													
month Maximum	0	0	0	0	0	0	0	0	0	0	0	0	0
month average	0	0	0	0	0	0	0	0	0	0	0	0	0
month minimum	0	0	0	0	0	0	0	0	0	0	0	0	0
day Maximum	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
day average	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
day minimum	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Export during high price hours													
month Maximum	0	0	0	0	0	0	0	0	0	0	0	0	0
month average	0	0	0	0	0	0	0	0	0	0	0	0	0
month minimum	0	0	0	0	0	0	0	0	0	0	0	0	0
day Maximum	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
day average	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
day minimum	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Export during medium price hours													
month Maximum	0	0	0	0	0	0	0	0	0	0	0	0	0
month average	0	0	0	0	0	0	0	0	0	0	0	0	0
month minimum	0	0	0	0	0	0	0	0	0	0	0	0	0
day Maximum	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
day average	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
day minimum	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Export during low price hours													
month Maximum	0	0	0	0	0	0	0	0	0	0	0	0	0
month average	0	0	0	0	0	0	0	0	0	0	0	0	0
month minimum	0	0	0	0	0	0	0	0	0	0	0	0	0
day Maximum	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
day average	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
day minimum	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

kWh exported while that price band was active. Not the money. Winter time. High 06:00–09:00 and 17:00–20:00, sold first. Low 09:00–15:00, sold last. Medium is the rest.

Heat pump
Germany - Grünheide 52.40100, 13.84200

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	All
Heating													
month Maximum	247	200	205	132	93	51	41	39	74	120	154	234	1429
month average	184	163	152	107	66	32	22	23	50	93	136	171	1199
month minimum	147	133	125	78	41	11	4	6	24	68	121	133	1089
day Maximum	12.1	11.6	8.6	10.1	9.6	9.1	8.5	8.3	9.4	6.0	7.5	9.5	12.1
day average	5.9	5.8	4.9	3.6	2.1	1.1	0.7	0.7	1.7	3.0	4.5	5.5	3.3
day minimum	0.0	2.8	1.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.4	2.3	0.0
Cooling													
month Maximum	0.00	0.00	0.00	0.00	0.00	1.83	10.34	8.47	1.13	0.00	0.00	0.00	11.94
month average	0.00	0.00	0.00	0.00	0.00	0.43	1.52	1.50	0.06	0.00	0.00	0.00	3.51
month minimum	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
day Maximum	0.00	0.00	0.00	0.00	0.00	1.48	5.80	5.16	1.13	0.00	0.00	0.00	5.80
day average	0.00	0.00	0.00	0.00	0.00	0.01	0.05	0.05	0.00	0.00	0.00	0.00	0.01
day minimum	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
DHW													
month Maximum	59	55	59	52	51	45	42	42	44	54	53	55	600
month average	59	53	58	50	48	43	40	41	42	52	53	55	592
month minimum	58	52	57	47	45	40	38	39	39	49	52	55	581
day Maximum	1.9	3.8	1.9	1.8	1.8	1.7	1.6	1.5	1.6	1.8	1.8	1.8	3.8
day average	1.9	1.9	1.9	1.7	1.5	1.4	1.3	1.3	1.4	1.7	1.8	1.8	1.6
day minimum	1.7	1.7	1.6	1.3	1.3	1.3	1.2	1.2	1.2	1.4	1.5	1.6	1.2
Direct electric													
month Maximum	0	0	0	0	0	0	0	0	0	0	0	0	0
month average	0	0	0	0	0	0	0	0	0	0	0	0	0
month minimum	0	0	0	0	0	0	0	0	0	0	0	0	0
day Maximum	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
day average	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
day minimum	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0


Heating, cooling and DHW are electricity. Direct electric is the part the heat pump could not cover.

Battery
Germany - Grünheide 52.40100, 13.84200


	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	All
Wasted													
month Maximum	207	1524	4067	6844	8562	8699	8540	7058	4634	2440	826	101	46899
month average	43	977	2882	5425	6865	7198	7022	5940	3897	1774	383	16	42422
month minimum	0	510	2198	4305	4099	5992	5592	4999	3010	905	123	0	39075
day Maximum	50.2	156.7	228.2	323.4	364.2	369.0	352.5	308.9	248.8	148.3	66.7	23.0	369.0
day average	1.4	34.9	93.0	180.8	221.5	239.9	226.5	191.6	129.9	57.2	12.8	0.5	116.2
day minimum	0.0	0.0	0.0	9.6	13.5	22.8	24.7	18.4	3.3	0.0	0.0	0.0	0.0
Full cycles													
month Maximum	4.26	3.60	3.46	2.65	2.56	2.26	2.35	2.39	2.51	3.36	3.78	4.33	36.15
month average	3.86	3.40	3.22	2.55	2.39	2.19	2.28	2.37	2.42	3.10	3.61	3.90	35.29
month minimum	3.67	3.13	3.08	2.47	2.24	2.12	2.23	2.34	2.34	2.95	3.42	3.05	34.16
day Maximum	0.18	0.24	0.14	0.11	0.11	0.09	0.09	0.09	0.10	0.13	0.15	0.16	0.24
day average	0.12	0.12	0.10	0.08	0.08	0.07	0.07	0.08	0.08	0.10	0.12	0.13	0.10
day minimum	0.03	0.08	0.09	0.07	0.07	0.07	0.07	0.07	0.08	0.08	0.10	0.03	0.03
Charge C													
month Maximum	0.08	0.09	0.08	0.09	0.08	0.08	0.08	0.07	0.07	0.08	0.07	0.06	0.82
month average	0.07	0.07	0.07	0.07	0.07	0.06	0.07	0.06	0.06	0.06	0.06	0.05	0.78
month minimum	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.05	0.05	0.75
day Maximum	0.08	0.09	0.08	0.09	0.08	0.08	0.08	0.07	0.07	0.08	0.07	0.06	0.09
day average	0.04	0.05	0.05	0.05	0.05	0.04	0.05	0.04	0.05	0.04	0.04	0.03	0.04
day minimum	0.00	0.01	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.01	0.01	0.00	0.00
Discharge C													
month Maximum	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.12
month average	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.12
month minimum	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.11
day Maximum	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01
day average	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01
day minimum	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.00	0.00

Wasted = PV left when the export price is negative and the battery is full. Full cycles = discharge kWh / 176.8 kWh. Battery export only into hours whose export price is above 0, highest price first. At 0 cent on

Battery cycles per day (discharge / 176.8 kWh)
Germany - Grünheide 52.40100, 13.84200



Battery max charge state per day (176.8 kWh = 100 %)
Germany - Grünheide 52.40100, 13.84200



Battery min charge state per day (176.8 kWh = 100 %)
Germany - Grünheide 52.40100, 13.84200

